Kodigehalli Improvements to crematoriums in ward No. 07

Basawalingappa Bhavana site



Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

⊠ - Basawalingappa Samudhayabhavana

Am An GEO CONSULTANT

NAGARAJ MOKASHI, MSc.,
GEOLOGIST

Mobile : 94483 13401
e-mail : ngmokashi@rediffmail.com
am.an4geoconsultant@gmailcom

Ramjyothi Nagar, R.V.College Post, Bangalore - 560 059.

To,
Assistant Executive Engineers
Projects, Yelahanka
BBMP.

Date : 01-02-19

GEO-TECHNICAL SURVEY REPORT
(Ground Water Exploration)

Sir / Madam,

As per your work order/request Geo-Hydrological / Geo-physical Survey carried out in your land / site belonging to Shri/Smt/M/s ..... city/village ..... Byatarayanapura ..... Dated on ..... 01-02-19 ..... in order to assess the ground water potential of the area for drinking / irrigation / industrial purposes.

The area inspected has a slope towards ..... marked by ..... Soil, uneven topography hydrogeological features are found to be favourable / not favourable for ground water extraction. Geology of the area revealed by ..... rock.

WATER EXTRACTED :

(I) ..... 300m ..... ft/mtrs. (II) ..... 250 ..... ft/mtrs.

(III) ..... 300m ..... ft/mtrs.

From the study of the above field observation, Investigation results, a borewell VES drilling ..... to app depth of ..... 300m ..... ft/mtrs. Below the ground level, Casing pipe required be to app depth of ..... 50m ..... ft/mtrs. Yield, yield expected may be around ..... 2" ..... GPH.

Suggested to drill 4 1/2" / 6 1/2" dia Borewell.

NOTE : Although the best site for drilling has been suggested, no guarantee of success can be given and we will not be liable in any way for any loss to the party in respect of the well drilled at the site recommended being a failure in any form.

Save Water

(NAGARAJ MOKASHI)

SAVE ENVIRONMENT ADOPT RAINWATER HARVESTING

Services : Ground Water location by geo-hydrological, geophysical and divining methods, Drilling advisors and supervision. Rainwater harvesting, water shed management, Quarry operations, Planning, Water testing, Soil Testing & Surveying.

Asst. Executive Engineer
Project Division
Yelahanka Zone

Vaibhavi Borewells

4½, 6½ Borewell Drillers

All kinds of Borewell Pumpsets Installation & Servicing of Jet Air Compressor, Submersible Pumps

No. 1, 1st Floor, Bhuvaneswari Nagar, R.T. Nagar Post, Bangalore - 560 032.
Mob : 9845003097 / 9900252226

Date :

YIELD TEST CERTIFICATE

Name of Well Owner : AEE-(Projects), Yelahanka.

Address : Basavalingappa samudhaya bharana - site.

Village / Hobli : Byatarayanapura.

Taluk : P -

District : Bangalore.

Survey No. of Land : 291/1/298

Date of Drilling : 04-02-19.

Depth of Casing Pipe : 50m

Size of Borewell : 6½'

Water Level : 280m

Remarks : Good Yeild.

Method of Test : V-drilling

Depth of Borewell : 311

Recommended Capacity Pump : 11.5Hp

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

For **Vaibhavi Borewells**

Proprietor

Supply Company Limited

6/16-02-2019

I2G1Z5

Office of
Assistant Executive Engineer
C8 SAHAKARANAGARA
BESCOM
DATE: 16-02-2019

IRA

er supply-NEW CONNECTION

o:204326437813 Dated: 15-02-2019

673437663

RC regulations.

204326437813 Dated: 15-02-2019, power supply to an extent of 0 KW
3 under LT basis, is hereby sanctioned, subject to the following:

	0
	0
	0
.m.	0
	0

BANGALORE ELECTRICITY SUPPLY COMPANY LTD

b. Total height of the building above ground level in m: 0

2. The **PROPOSED** Sanctioned Load of your building is **12.682 KW**

Existing Load Details of your premises:

1	Existing Sanctioned Load	0
2	New/ Additional Load Required	0 KW and 17 HP
3	Total Load	12.682 KW

You are requested to pay the following charges by Cash/ DD (above ₹10000/-, only DD will be acc
favour of **The Assistant Executive Engineer (El) C8 SAHAKARANAGARA, BESCOM** within 30
date of this letter:

Sl. No.	Particulars	Amount
1.	2 MMD to be for 1 Nos (of **0 KW** and **17 HP**) installation	₹14630.00
2.	MSD Amount	₹0.00
3.	Infrastructure Charges	₹0.00
4.	Service Line Cost(Development Charge)	₹0.00
5.	Additional Development /Service Line Charges	₹0.00
6.	CGST Amount	₹0.00
7.	SGST Amount	₹0.00
	Total	₹14630.00

Note: 2 MMD/MSD shall be paid separately for individual installations (separate Payment Receipts to

3. The power supply will be arranged at 400V

4. The Power Tariff applicable to your proposed installation will be **Monthly LT6A tariff schedule fo customers(BESCOM)** Tariff, or as in force from time to time

5. You have to confirm to purchase High precision/Electrostatic meters/ETV meters of the following

a) Single Phase Meters _____Nos.

b) Three Phase Meters _____Nos.

c) ETV Meters _____ Nos.

d) TP box with _____CTR _____Nos.

6. After the payments, the following requirements may please be fulfilled:

a) Execute agreement of power supply on ₹200/- Stamp Paper in duplicable, for individual install in the prescribed format

b) Produce necessary License/Permit/No Objection Certificate etc., issued by the Competent Au required under the statute

7(a) The Power supply will be arranged by **BESCOM** as below:

a) From the existing _KVA Transformer

b) After enhancement of TC capacity from KVA to 0 KVA of the TC located at

(a) After erecting new 0 KVA transformer under service connection

If you intend to install distribution transformer inside your premises, and execute the work under self-... to avail above power supply, the following shall be complied:

i. An electrical room with RCC roof having clear floor area of 5 metres X 4 metres, with a vertical clearance of 2.75 meters with locking facility, exhaust fans and adequate size of cable duct, shall be provided at the ground floor, within the Applicant's premises nearer to the main entrance, for installing floor mounted distribution transformer and associated switchgear, or

ii. A clear space of 3 metres X 5 metres open to the sky shall be provided, within the Applicant's premises, preferably at the main entrance, for installing structure mounted distribution transformer and switchgear

... approved suitable capacity circuit breaker, ELCB & switchgears shall be used, and all the provisions ... KERC Regulations 4.03 and 4.04 shall be complied

... reserves the right to cancel power supply and forfeiting of the Deposits paid by you, if the documents ... by you are found to be fake

... the Govt. Order, solar water heaters of suitable capacity shall be provided

... Nos. of Compact Fluorescent Lamps shall be used for each installation

... metering equipment to be installed should be conspicuously visible and at the main entrance to the ... preferably with an independent entrance.

... requested to contact the undersigned in case of any other information that may be required by you.

... at your services.

Yours faithfully

Assistant Executive Engineer

C8 SAHAKARANAGARA

BESCOM

TAX INVOICE

(See Rule 46 of the Central Goods & Services Tax Rules, 2017)

Landis+Gyr Limited

ಲ್ಯಾಂಡಿಸ್+ಗೇರ್ ಲಿಮಿಟೆಡ್

Landis+Gyr

[illegible] 3rd Main,
[illegible] Hanumanthnagar,
[illegible] 560050.

Branch Office Address :
O/o AEE (C, O&M), E-5 Sub-Division,
BESCOM, 3rd Block, HBR Layout,
BENGALURU - 560008.

ABB BBMP
HeRBal.
B-lore.

BILL No. **LRP/18/** 04697

DATE : 01/03/19 TIME 12:00 AM/PM

GSTIN : 29AAACV9922B1ZA

Description of Goods / Services	Quantity (Nos.)	Rate per Pc Rs.	Value Amount Rs.	P.
HSN Code : 90283010 Three Phase Static Energy Meter E150 / E250, 5-30 Amps Serial Nos. C807444	1	1466-67	1466	67
		CGST @ 9%	132	00
		SGST @ 9%	132	00
		GRAND TOTAL	1730	67

C-4
B-11540 Date 27/02/19

One Thousand Seven Hundred & Sixty seven paise.

1st Copy Original : White
2nd Copy Duplicate : Pink
3rd Copy Triplicate : Yellow
4th Copy Extra : Blue

For Landis+Gyr Limited

Signature

Asst Executive Engineer
Project Division
Yelahanka Zone

Kodigehalli

Sahakaranagara park



Map data ©2019 Google 50 m

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

- Borewell location

Am An GEO CONSULTANT

NAGARAJ MOKASHI, MSc.,
GEOLOGIST

Mobile : 94483 13401
e-mail : ngmokashi@rediffmail.com
am.an4geoconsultant@gmailcom

Ramjyothi Nagar, R.V.College Post, Bangalore - 560 059.

To,

Assistant Executive Engineer,
Projects, Yelahanka
BBMP

Date : 01-02-19

GEO-TECHNICAL SURVEY REPORT
(Ground Water Exploration)

Sir / Madam,

As per your work order/request Geo-Hydrological / Geo-physical Survey carried out in your land / site belonging Bangalore city/village Byatarayanapura Yelahanka Dated on 01-02-19 in order to assess the ground water potential of the area for drinking / irrigation / industrial purposes.

The area inspected has a slope towards ..... marked by ..... Soil, uneven topography hydrogeological features are found to be favourable / not favourable for ground water extraction. Geology of the area covered by ..... rock.

RESOURCES EXTRACTED :

(I) between 150 m ft/mtrs. (II) 200 ft/mtrs.

(III) 260 m ft/mtrs.

From the study of the above field observation, Investigation results, a borewell VES drilling ..... to app depth of 270 m ft/mtrs. Below the ground level, casing pipe required be to app depth of 50 m ft/mtrs. Approx. yield expected may be around 3" GPH.

Suggested to drill 4 1/2" / 6 1/2" dia Borewell.

NOTE : Although the best site for drilling has been suggested, no guarantee of success can be given and we will not be liable in any way for any loss to the party in respect of the well drilled at the site recommended being a failure in any form.

Save Water

(NAGARAJ MOKASHI)

SAVE ENVIRONMENT ADOPT RAINWATER HARVESTING

Services : Ground Water location by geo-hydrological, geophysical and divining methods, Drilling advisors and supervision. Rain water harvesting, water shed management, Quarry operations, Planning, Water testing, Soil Testing & Surveying.

Asst. Executive Engineer
Project Division
Yelahanka Zone

Vaibhavi Borewells

4½, 6½ Borewell Drillers

Dealers : All kinds of Borewell Pumpsets Installation & Servicing of Jet Air Compressor, Submersible Pumps

No. 1, 1st Floor, Bhuvaneswari Nagar, R.T. Nagar Post, Bangalore - 560 032.
Mob : 9845003097 / 9900252226

Ref:

Date: 05-02-19

YIELD TEST CERTIFICATE

Name of Well Owner	:	AEE, projects, Yelahanka zone.
Address	:	sahakaranagara 'E' block - park.
Village / Hobli	:	Byatasayanapura.
Taluk	:	-
District	:	Bangalore.
Survey No. of Land	:	
Date of Drilling	:	05-02-19
Depth of Casing Pipe	:	50m
Size of Borewell	:	6½'
Water Level	:	270m
Remarks	:	-
Method of Test	:	V-drilling
Yield of Borewell	:	2"
Recommended Capacity Pump	:	1.5HP

For **Vaibhavi Borewells**

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

Proprietor